

78 Pleasant Avenue, South Portland, ME

REPORT OF ANALYSIS

Vessel KTC-90
Port/Terminal Sprague, Searsport, ME
Client Reference V-04-00629
Our Reference 2004-0240
Date Sample Taken 09/04/04
Date Submitted 09/04/04
Date Tested 09/04/04
Sample Designated as # 6 Fuel Oil
Drawn By Intertek Testing Services Caleb Brett
Representing Shore Tank 3

Lab Reference Number

Test	Method	Results	Units
Gravity / Density @ 15C	ASTM D 4052	10.8 / 0.9939	API @ 60F / kg/l
Flash Point	ASTM D 93A		F / C
Viscosity at 122 F	ASTM D 445/2161	599.8 / 2778	cSt / SUS
Cloud Point	ASTM D 2500		F / C
Pour Point	ASTM D 97		F / C
Sediment & Water by Cent.	ASTM D 2709		% Volume
Sulfur	ASTM D 4294-98	1.75	% Weight
Cetane Index	ASTM D 976		Calculated
Ash	ASTM D 482		Weight %
Conductivity @ 40F	ASTM D2624		pS/m
Dye	DT-100		ptb/ppm
Distillation	ASTM D 86		
	IBP		F
	10% Rec.		F
	50% Rec.		F
	90% Rec.		F
	EBP		F
	Recovered		% Volume
	Residual		% Volume
	Loss		% Volume

SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.

Walter Lach, Intertek Caleb Brett